

ADDENDUM NO.1

March 12, 2018

PROJECT NAME: Tyhee Elementary School HVAC Revisions

The data included hereinafter is issued by the Engineer (Engineered Systems Associates, Inc. 1355 East Center St., Pocatello, ID 83201) as clarification, addition to, and/or deletion from the Drawings, Specifications, and Contract Documents relative to the above-named project.

Except as affected by data included hereinafter, all other parts of the Contract Documents shall remain in full force and effect as issued by the Engineer. It shall be the sole responsibility of the Bidder to appropriately disseminate this data to all concerned prior to the assigned bid time and date. Receipt of the addendum shall be recorded by the Bidder in the appropriate space on the Bid Form included in the Contract Documents.

Specifications:

1. See Attached list of Pre-Bid Walk-Thru Attendees.
2. Existing Roof does not have a Warrantee – Contractor can contact Modern Roofing (208) 232-2504 or another Roofer for any patch or repair required under this project.

Drawings:

1. Sheet ME1.3 – Plan Note⑤: See Detail on Sheet ME3.1.
2. Sheet ME2.3 – Plan Note⑤: See Detail on Sheet ME3.1.
Sheet ME2.1, ME2.2 Note⑬: Contractor, may, at their option, take Outside Air Intake from Sidewall Parapet Walls as this area has a Higher Roof. Use 24 x 12 Outside Air Louver equal to American Warming LE-21. Maintain 10' clearance from any Plumbing or Mechanical Vent.
3. Sheet ME 2.1, ME2.2 Note⑮: Contractor may, at their option take the Flues out Sidewall Parapet Walls as this area has a higher Roof. Use Sidewall Concentric Vent as per Furnace Manufacturer.

END OF ADDENDUM

Tyhee Elementary School HVAC Replacement

2-27-18 - Attendance Sheet

Request
Hand
COPY

Name	Company Name	Phone	E-Mail
JACOB MECHAN	MECHAN Automation	208-681-9130	Jake@mechanautomation.com
Eric Turner	Mechanical Solutions	208-760-7246	Eric@MechSolutions.co
Mason Lewis	Lewis Corporation	208-238-1202 x105	mason@lcorp.com
Steve Bill	Upstream Plumbing	208-681-4169	Billmans2@aol.com