

**POCATELLO/CHUBBUCK  
SCHOOL DISTRICT NO. 25  
Bannock County, Idaho**

March 4, 2016

**Addendum No.1**

RE: HVAC Bid  
School District No. 25  
Pocatello, Idaho 83201

FROM: C. B. Giles  
Business Services Coordinator  
3115 Poleline Road  
Pocatello, Idaho 83201  
(208) 235-3220  
gilescb@d25.k12.id.us

This Addendum becomes a part of the Contract Documents and modifies the original Bidding Specifications, as noted below. Acknowledge receipt of this Addendum on the original Bid Form. Failure to do so may subject the Bidder to disqualification.

Please make the following change to the HVAC Bid Specifications. No other changes are made to the original bidding specifications:

The new condenser to be installed at Washington Elementary School is to use 208 volt. The electrical panel that will feed this unit is 3 phase so the unit can be single or 3 phase.

NO OTHER CHANGES  
END OF ADDENDUM No.1 – 030416 cbg